



Mr. Matthew Iida  
Little Firefighter Corporation  
204 S. Center Street  
Santa Ana, CA 92703

January 30, 2020

RE: Earthquake Sensitive Automatic Gas Shutoff Valves (ESV) Certification

Dear Mr. Iida:

The Division of the State Architect (DSA) received your application of certification for Earthquake Sensitive Automatic Gas Shutoff Valves (ESV) under ASCE/ANSI/SEI 25-16. DSA has issued your product new certification numbers to identify the year of compliance with the 2019 California Plumbing Code when the new testing standard (ANSI/ASCE/SEI 25-16) was required. Starting January 1, 2020, the newly issued DSA number will need to be marked on each ESV.

The submitted test reports number 1173165, dated 01/17/20, and test report PR110747, dated 01/08/20, have been verified by DSA. DSA certification is contingent upon the following:

1. The CA-DSA label shall appear on the valve's markings and the container in compliance with Section 1378, Subchapter 6, Title 21, California Code of Regulations (CCR) labeling requirements. The valves and container shall be marked with the following DSA number:

Product numbers: VAGV – 075, VAGV – 100, VAGV – 125, VAGV – 150, VAGV – 200  
VAGV – 125 HF,  
AGV – 150 HP, AGV – 200 HP  
AGV – 075, AGV – 100, AGV – 125, AGV – 150, AGV – 200, AGV – 250,  
AGV – 300 and AGV – 400  
NAGV – 075, NAGV – 100, NAGV – 125  
VAGV – 150 HP, VAGV – 200 HP  
DSA label assigned: **DSA 19-S08**

Product numbers: FAGV – 300, FAGV – 400, FAGV – 600  
DSA label assigned: **DSA 19-S10**

2. All ESV's are subject to independent third party quality control inspections conducted as required by Section 1382(a), Title 21, CCR. Inspections may be made a minimum of four times a calendar year by a DSA certified Inspection Service Agency as required by Section 1382(e) and copies of the verified inspection reports are to be sent to DSA within 30 days of date of inspection as required by Section 1382 (f) Title 21, CCR.
3. Any changes in or to the certified valve or manufacturing procedures require a new certification unless DSA has granted a modification to the certification per Section 1374.

Sincerely,

**Tav Commins**  
Senior Mechanical Engineer  
[Tav.Commins@dgs.ca.gov](mailto:Tav.Commins@dgs.ca.gov)  
Phone: 916-443-9841

